

CITY OF LOS ANGELES
CALIFORNIA

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012



JAVIER NUNEZ
PRESIDENT

ELVIN W. MOON
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
LAUREL GILLETTE
GEORGE HOVAGUIMIAN

ERIC GARCETTI
MAYOR

OSAMA YOUNAN, P.E.
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

JOHN WEIGHT
EXECUTIVE OFFICER

STRONGWELL
400 Commonwealth
Bristol, VA 24203-0580

Attn: Joe Spanovich,
Manager of Engineering and Quality
(276) 645-8155

Local Representative:
Bill Faust
(276) 645-8155

RESEARCH REPORT: RR 25698

Expires: June 1, 2024
Issued Date: September 1, 2022
Code: 2020 LABC

GENERAL APPROVAL – Renewal - Strongwell FRP RF Panel Enclosure System for rooftop communication antenna screening.

DETAILS

The Strongwell enclosure system consists of Extren® pultruded fiberglass reinforced structural shapes, Durashield® and Safplank® pultruded with spans between structural supports. Connections between the pultruded structural shapes and cladding members are accomplished by means of FRP threaded rod and fiberglass thermoplastic nuts. The material specifications are as follows:

1. Extren® Pultruded Structural Shapes: Fiberglass reinforced plastic shapes formed by the pultrusion method. The minimum properties for the pultruded shapes are listed in Table 1.
2. Durashield® , Extren® flatplate and Safeplank® which are also made by the pultrusion process with bi-directional strength.
3. ½" FRP threaded rods.
4. Fiberglass reinforced thermoplastic nuts.

RR 25698
Page 1 of 4

The approval is subject to the following conditions:

1. Extren® 1/4" flate plates, Durashield® and/or Safplank® cladding members are connected to the frame by means of 1/2" FRP threaded rods and fiberglass reinforced thermoplastic nuts. When supported as described the allowable load for a 6-ft by 8-ft framed panel is 40 psf (pounds per square foot).
2. Extren® Structural Shapes applied as beams: The design values are in Table 1.

TABLE 1 - Design values for FRP

Property	Direction	Specification
Tensile	Lengthwise Crosswise	5881 psi 1606 psi
Tensile Modulus	Lengthwise Crosswise	3.62 x 10 ⁶ psi 0.97 x 10 ⁶ psi
Flexural	Lengthwise Crosswise	6588 psi 2612 psi
Flexural Modulus	Lengthwise Crosswise	1.88 x 10 ⁶ psi 1.18 x 10 ⁶ psi
Shear	Horizontal	904 psi
½" bolt bearing	Lengthwise Crosswise	5475 psi 2105 psi
Minimum edge distance		1.5 - inch

Note: Design value is based on a factor of safety of 8

3. Complete plans and structural calculations prepared by a California licensed architect or civil or structural engineer and shall be submitted to the department for approval prior to permit issuance.
4. The Fire Department shall approve all plans for plastic screening on Title 19 buildings.
5. Antennas and screening must not obstruct access to the roof by the Fire Department as required by Sec 57.12.04 of the Los Angeles Municipal Code which states: No person shall obstruct required access passageways on the roof surface. An unobstructed passageway for use by the Fire Department shall be provided through or around any approved structures or equipment installations on the roof surface. One access passageway shall be provided for every 50-foot length or fraction thereof of roof surface. Passageways shall be at least three feet wide and have at least seven feet of overhead clearance.

STRONGWELL

RE: Strongwell Panel Enclosure System

6. The individual rooftop screening panel area in any one plane or approximately the same plane shall be limited to 250 square feet and the total maximum aggregate area of all panels shall not exceed the larger of 3 square feet per foot of building frontage or 5 percent of the area of the roof, with a maximum allowable height of 18 feet above the roof level.
7. Screening material shall be located at least 20 ft from interior property lines for Type I, II, III, and IV buildings per 2020 LABC section 1510.6.2, Item 2.
8. Screening material shall be located at least 5 ft from interior property lines for Type V buildings per 2020 LABC section 1510.6.3, Item 3.
9. Screening shall not be illuminated or electrified.
10. Each panel shall be identified with LARR #25698 and Strongwell Label.
11. The fabrication will be in accordance with manufacturer's quality control manual. A copy of the quality control manual is on file with Engineering Research Section.

DISCUSSION

The report is in compliance with the 2020 Los Angeles City Building Code.

The approval is based on LADBS Acceptance Criteria L182

The approval is based on tests per section 1510.6.2 and 2303.2 of the 2020 LABC, which show that the approved materials exhibit performance that is equivalent to fire-retardant treated wood.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

STRONGWELL

RE: Strongwell Panel Enclosure System

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this Approval have been met in the project in which it is to be used.

EUGENE BARBEAU, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Email- engineering-research@lacity.org

EB
RR25698
TLB2200122
R09/12/2022
1510.6//2612